

Aflæsning af forbrug af strøm og varme til varmepumpen Aars golfklub

Dato	Kl.	Ude temp	Strøm KW	Varme MW	Anvendt varme MW	Køle COP	Varme COP*	Akk. varme COP	Evt. bemærkninger
06-feb-14	11:35	6	34820	21,111	55,931	3,57	4,57	4,57	
07-feb-14	10:15	4	34900	21,397	56,297	3,52	4,52	4,53	
10-feb-14	11:55	7	35160	22,312	57,472	3,49	4,49	4,53	
11-feb-14	10:45	5	35239	22,588	57,827	3,46	4,46	4,51	
12-feb-14	10:55	5	35322	22,875	58,197	3,49	4,49	4,51	
13-feb-14	11:30	6	35414	23,196	58,61	3,48	4,48	4,51	
14-feb-14	11:10	6	35497	23,485	58,982	3,48	4,48	4,50	
17-feb-14	10:40	7	35732	24,302	60,034	3,39	4,39	4,49	
18-feb-14	12:40	8	35804	24,546	60,35	2,87	3,87	4,38	
21-feb-14	10:05	8	36022	25,172	61,194	2,99	3,99	4,31	
25-feb-14	11:20	7	36261	25,887	62,148	3,46	4,46	4,32	
26-feb-14	10:55	9	36330	26,126	62,456	3,28	4,28	4,32	
27-feb-14	10:10	7	36388	26,316	62,704	3,42	4,42	4,32	
28-feb-14	10:30	7	36460	26,562	63,022	3,43	4,43	4,34	
03-mar-14	10:45	7	36671	27,286	63,957	3,42	4,42	4,34	
04-mar-14	10:20	5	36743	27,532	64,275	3,41	4,41	4,34	
05-mar-14	11:40	8	36817	27,784	64,601	3,44	4,44	4,34	
06-mar-14	11:15	8	36888	28,028	64,916	3,52	4,52	4,35	
07-mar-14	10:15	10	36953	28,257	65,21	3,41	4,41	4,35	
10-mar-14	10:20	10	37142	28,901	66,043	3,39	4,39	4,36	
11-mar-14	10:30	8	37206	29,118	66,324	3,32	4,32	4,35	
12-mar-14	11:10	10	37271	29,334	66,605	3,27	4,27	4,35	
13-mar-14	12:25	11	37337	29,55	66,887	3,23	4,23	4,35	
14-mar-14	10:35	9	37389	29,718	67,107	3,41	4,41	4,35	
17-mar-14	10:10	12	37574	30,349	67,923	3,44	4,44	4,36	
18-mar-14	11:45	11	37637	30,566	68,203	3,37	4,37	4,36	
19-mar-14	10:30	9	37694	30,758	68,452	3,39	4,39	4,36	
20-mar-14	10:30	12	37751	30,951	68,702	3,16	4,16	4,35	
21-mar-14	10:30	11	37795	31,09	68,885	3,36	4,36	4,35	
24-mar-14	12:30	12	37976	31,699	69,675	2,66	3,66	4,34	
25-mar-14	12:25	10	38034	31,853	69,887	3,15	4,15	4,34	
26-mar-14	10:35	4	38093	32,039	70,132	3,21	4,21	4,34	
27-mar-14	10:30	6	38166	32,273	70,439	3,81	4,81	4,34	
28-mar-14	10:35	10	38223	32,49	70,713	3,10	4,10	4,33	Data rettet fra 38323 til 38223
31-mar-14	11:35	9	38399	33,036	71,435	3,25	4,25	4,33	
01-apr-10	12:15	11	38458	33,228	71,686	3,18	4,18	4,33	
02-apr-14	12:10	7	38523	33,435	71,958	3,27	4,27	4,33	
03-apr-14	11:45	10	38583	33,631	72,214	3,21	4,21	4,33	
04-apr-14	11:50	9	38641	33,817	72,458	3,29	4,29	4,32	
07-apr-14	12:30	10	38814	34,387	73,201	3,18	4,18	4,32	
08-apr-14	12:30	12	38853	34,511	73,364	3,20	4,20	4,32	
09-apr-14	12:20	14	38904	34,674	73,578	3,20	4,20	4,32	
10-apr-14	13:30	12	38958	34,847	73,805	3,43	4,43	4,32	
11-apr-14	11:50	13	39002	34,998	74	3,14	4,14	4,23	
14-nov-14	10:50	10	43189	48,144	91,333	3,08	4,08	4,22	
28-nov-14	07:12	6	44124	51,027	95,151	3,08	4,08	4,19	
19-dec-14	10:20	7	45849	56,347	102,196	2,81	3,81	4,09	
02-feb-15	13:15	5	50094	68,277	118,371	2,26	3,26	3,97	
27-feb-15	10:30	7	52734	74,231	126,965	2,90	3,90	3,96	
27-mar-15	11:10	10	54602	79,654	134,256	3,06	4,06	3,97	
04-maj-15	13:00	15	56655	85,942	142,597	3,03	4,03	3,97	
01-jun-15	12:15	17	57779	89,351	147,13	2,70	3,70	3,96	
30-jun-15	11:30	21	58688	91,806	150,494	2,20	3,20	3,93	
31-jul-15	12:15	19	59623	93,86	153,483	6,85	7,85	3,96	
31-aug-15	13:10	19	59807	95,121	154,928	2,94	3,94	3,96	
29-sep-15	11:00	14	60631	97,546	158,177	-56,68	-55,68	0,30	
02-nov-15	11:30	13	62319	1,867	64,186	3,00	4,00	0,51	
30-nov-15	11:50	6	63962	6,794	70,756	3,02	4,02	0,82	
05-jan-16	11:00	0	66803	15,376	82,179	2,66	3,66	1,06	
01-feb-16	12:30	4	69793	23,326	93,119	2,57	3,57	1,28	
04-mar-16	12:30	6	73016	31,619	104,635	2,81	3,81	1,47	
14-apr-16	16:00	13	76270	40,772	117,042	-0,22	0,78	4,23	
		10	43189	48,144	91,333	#DIV/0!	#DIV/0!	4,23	
		10	43189	48,144	91,333	#DIV/0!	#DIV/0!	4,23	
		10	43189	48,144	91,333	#DIV/0!	#DIV/0!	4,23	
		10	43189	48,144	91,333	#DIV/0!	#DIV/0!	4,23	
		10	43189	48,144	91,333	#DIV/0!	#DIV/0!	4,23	
		10	43189	48,144	91,333	#DIV/0!	#DIV/0!	4,23	
		10	43189	48,144	91,333	#DIV/0!	#DIV/0!	4,23	
		10	43189	48,144	91,333	#DIV/0!	#DIV/0!	4,23	
		10	43189	48,144	91,333	#DIV/0!	#DIV/0!	4,23	
		10	43189	48,144	91,333	#DIV/0!	#DIV/0!	4,23	
		10	43189	48,144	91,333	#DIV/0!	#DIV/0!	4,23	
		10	43189	48,144	91,333	1,11	2,11	1,61	

*Aflæsning af varme sker på fjernvarmemåler. Beregnet COP er derfor en køle COP. Omregning til varme COP er givet ved: Varme COP = Køle COP + 1